

By eMARYLAND MARKETPLACE (eMM) ONLY

ADDENDUM NO. 2

**TO THE CONTRACT DOCUMENTS FOR THE
BCDC YOUTH DETENTION CENTER
at the
Baltimore City Detention Center
in the
Division of Pretrial Detention and Services (DPDS)**

**STATE OF MARYLAND
CONTRACT NUMBER: KT-000-150-C01**

DATE OF ISSUE: FEBRUARY 13, 2015


To All Bidders: This Addendum is intended to modify, explain, correct and/or delete the provisions of the original Contract Documents issued February 5, 2015, and previously-issued Addenda, and is hereby (unless noted otherwise) made a part of the Contract Documents on which the Construction Contract will be based.

Acknowledge receipt of the Addendum by inserting its number and date in the Construction Bid Form. Failure to do so may subject the bidder to disqualification.

Addendum No. 2 consists of a total of two (2) 8½" x 11" pages.

- I. Addendum
- II. Attachments: N/A

Issued by:



Carl L. Lazerow, Director and Procurement Officer
Division of Capital Construction and Facilities Maintenance
Department of Public Safety and Correctional Services
State of Maryland
6776 Reisterstown Road Suite 201
Baltimore, MD 21215-2341
Telephone: 410-585-3021

Prepared by: PSA-Dewberry + Penza Bailey Architects, A Joint Venture
401 Woodbourne Avenue
Baltimore, MD 21212

A. Clarifications and General Bidders' Questions (THESE ARE INTENDED ONLY TO CLARIFY PROVISIONS OF THE CONTRACT DOCUMENTS BUT DO NOT MODIFY THEM):

2.1. Per the Contract Documents, no substitutions will be entertained during the bidding period. After Contract award, alternate approaches or substitutions may be reviewed in accordance with the procedures outlined in Section 01 25 00 SUBSTITUTION PROCEDURES. Lists of products and manufacturers in the specifications are in the form of either a Restricted List or a Nonrestricted List, as defined in Section 01 60 00 PRODUCT REQUIREMENTS. In the case of a Nonrestricted List, submission of an unnamed product or manufacturer does not require a substitution or change to the Contract Documents, but must comply with requirements for "Comparable Products" as outlined in that Section. Proposed changes to a Restricted List shall be in accordance with Section 01 25 00 SUBSTITUTION PROCEDURES.

B. Drawings

N/A

C. Project Manual

2.2.	<p>Section 08 88 53 SECURITY GLAZING, Part 2 – Products, 2.2 SECURITY GLAZING TYPES: Replace Paragraph H with the following revised Paragraph H:</p> <p>H. SG-16R: Fire Resistance Rated Glass Clad Polycarbonate; air gap; laminated fire rated glazing, 1-13/16-inch nominal thickness.</p> <ol style="list-style-type: none"> 1. Consisting of tempered or chemically strengthened glass, polycarbonate cores; and chemically strengthened glass. Laminated with two layers of special interlayer material. 2. Provide applied tinting "film" at interior of all control room areas. Tint color, reflectance, and darkness to be selected by Architect from manufacturer's full range of tinting options. 3. Master and Local Control Glazing Tinting Film Selection: Provide (3) three progressive in situ window tint combination mockups once glazing and lights are installed in Control Rooms. Initial mockup to provide a minimum of 4 different tint levels on each side of the Control Rooms to determine the appropriate tint combination for final installation. First and second round mockups to be 12"x12" installed samples. Final mockup to be 24"x24" installed samples. 4. Fire Rating: 20 minute minimum required. 5. Forced-Entry Resistance: ASTM F-1915 Security Grade 1(60 Minute) 6. Basis of design: Global Security Glazing Ultimax 45.
2.3.	<p>Section 11 19 63 DETENTION FURNISHINGS AND EQUIPMENT, Part 2 – Products, 2.26 DETENTION ACCESS PANEL (DAP): Add Paragraph G:</p> <p>G. Furnish and install 20 additional 24"x24" Detention Access Panels in addition to what is required on the drawings. Final size and location of installation to be directed by General Contractor after coordinating with the MEP sub-contractors and shop drawings.</p>

END of ADDENDUM NO. 2